

BIORETENTION CELL:	
Bioretention cell is free of trash & debris.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Surrounding pervious areas are free of bare soil & erosive gullies.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Inlet pipe is free of clogs, cracks, & other damage.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Swale is free of erosion.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Stone verge is free from clogging & sediment.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Pretreatment area is free of weeds & erosion.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Depth of sediment accumulated in the pretreatment area is ≤ 3 inches.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
There is no evidence to suggest that flow is bypassing the pretreatment area.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Vegetation is well established & healthy.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Cell is free of weeds.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Mulch layer is uniformly distributed & 2-4 inches deep.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
pH is approximately 5.5-7.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Soils and/or mulch is free from sediment clogging.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Underdrain & outlet system are free from clogging & damage.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Drop inlet is intact & functioning properly.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
There is no evidence of erosion at the outlet.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Under design volume conditions, discharged water is free of visible pollution.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Discharge is not causing sedimentation or erosion in receiving water.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:

Summary of maintenance required to address any “No”(s):