

<b>LEVEL SPREADER-FILTER STRIP (LS-FS):</b>	
LS-FS is free of trash & debris.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Flow splitter device is free of clogs & damages.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
There is no sediment accumulation on the FS or the bottom of the blind swale.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Vegetation in the swale is approximately 6 inches in height.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Vegetation in the SF is approximately 3-6 inches in height.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
LS lip is free of cracks, undercuts, & other damages.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
There are no signs of erosion to suggest that stormwater is bypassing the LS.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Blind swale & area immediately downslope of the LS are free of trees & woody vegetation.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Bypass channel & FS are free of erosion & bare soil.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Riprap stays in place.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Turf reinforcement is free of damages.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Vegetation on FS is not choking out the grass.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Grass & vegetation are established & healthy.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Discharge is not causing sedimentation or erosion in the receiving water.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Under design volume conditions, discharged water is free of visible pollution.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:

**Summary of maintenance required to address any “No”(s):**