

SAND FILTER:	
Sand filter is free of trash & debris.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Pavement surface is free of weeds & sediment.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Surrounding pervious areas are free of erosive gullies & bare soil.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Perimeter vegetation is maintained at an appropriate height.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Flow diversion structure is free of clogs & damage.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Depth of sediment accumulated in the sediment chamber is ≤ 6 inches	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Sediment chamber is free of erosion & weeds.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Sand chamber is free from ponding 24 hours after a storm event.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Outlet device is free of clogs & damage.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
No signs of erosion at the outlet.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Under design volume conditions, discharged water is free of visible pollution.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Discharge is not causing sedimentation or erosion in the receiving water.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:

Summary of maintenance required to address any “No”(s):