

STORMWATER WETLAND:	
Wetland is free of trash & debris.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Surrounding pervious areas are free from erosive gullies & bare soil.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Inlet is free of clogs & damage.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Inlet swale is free of erosion.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Forebay is free of weeds.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Forebay is functioning properly with a depth of \geq 15 inches.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Forebay is free of erosion.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Algae covers \leq 30% of the deep pool(s) & shallow water zone(s).	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Cattails, phragmites & other invasive plants cover \leq 30% of the deep pool(s) & shallow water zone(s).	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Water level returns to permanent pool design level within 5 days of a storm event.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Vegetation in deep pool(s), shallow water zone(s) & shallow land area(s) are healthy.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Despite sediment accumulation, the deep pool(s) remains within 25% of the original design depth.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Embankment is free of trees & woody shrubs.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Embankment is free of muskrat & beaver activity.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Despite sediment accumulation, the micropool remains within 25% of the original design depth.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Outlet structure is free of clogs & damage.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
No signs of damage or erosion at the outlet.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
There is stable groundcover in the drainage area.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Discharge is free of visible pollution.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:
Discharge is not causing sedimentation or erosion in the receiving water.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Comments:

Summary of maintenance required to address any “No”s: