



CUT SLOT TO INSERT #12 BLUE OR GREEN INSULATED COPPER TRACER WIRE - 6" FROM FINISHED GRADE

PART	MANUFACTURER MODEL / Cat. No.
VALVE BOX	SOUTHERN FOUNDRY 562A EAST JORDAN IRON WORKS 49D6-20

⚠ Provide 1" earth cushion between bottom of concrete brick and valve. Do not let valve box or brick rest on valve assembly. – Typical all valves.

NOTES:

1. Use heavy duty traffic lid marked "WATER" OR "SEWER".



TOWN of CLAYTON

USE WITH THE TOWN of CLAYTON STANDARD SPECIFICATIONS ONLY

**STANDARD SCREW VALVE
BOX DETAIL**

SCALE: Not To Scale	DETAIL # 2513.01
REVISION DATE: APRIL, 2014	SHEET #: 1 of 1