

| General Information |     |                                | Cause                                |          |         |      | Customers |              |
|---------------------|-----|--------------------------------|--------------------------------------|----------|---------|------|-----------|--------------|
| Date                | P/U | Feeder / Address               | Description                          | Time Off | Time On | Mins | # Out     | Cust Minutes |
| 2/3/2016            | U   | EAST / Walden Way              | Tree on line caused two blown fuses  | 10:30am  | 11:30am | 60   | 95        | 5,700        |
| 2/6/2016            | U   | CENTRAL / 412 N. O'Neil Street | Tree rubbed secondary in half        | 6:40pm   | 8:40pm  | 120  | 2         | 240          |
| 2/13/2016           | U   | CENTRAL / 556 N. Church Street | Bad Underground                      | 3:45pm   | 6:22pm  | 157  | 6         | 942          |
| 2/24/2016           | U   | SOUTH / 1108 Cardinal Court    | Tree on line caused blown fuse       | 5:15pm   | 6:00pm  | 45   | 20        | 900          |
| 2/26/2016           | U   | EAST / 10368 US 70 Bus W       | Secondary block in CT cabinet failed | 9:00am   | 10:40am | 100  | 1         | 100          |

P=Planned

U=Unplanned