

General Information			Cause				Customers	
Date	P/U	Feeder / Address	Description	Time Off	Time On	Mins	# Out	Cust Minutes
6/4/2016	P	CENTRAL / 622 S. Barbour Street	Replaced Pole	6:00am	10:00am	240	1	240
6/7/2016	U	SOUTH / 404 Dairy Road	Bad Underground	7:20pm	11:20pm	240	56	13,440
6/8/2016	U	WEST / 416 Brook Drive	Blown Fuses	7:00am	8:30am	90	50	4,500
6/15/2016	U	EAST / Skymont Drive	Bad spot in cable at elbow	8:45am	9:05am	20	150	3,000
6/19/2016	U	EAST / 900 Neuse Ridge Drive	Bad Underground	12:30pm	2:00pm	90	1	90
6/29/2016	U	CENTRAL / 516 E. Blanchard Street	Limb fell on primary; blown fuse	6:30pm	8:00pm	90	40	3,600

P=Planned

U=Unplanned